

**RESOURCE INTERNATIONAL, LTD.  
9560 KINGS CHARTER DRIVE  
P.O. BOX 6160  
ASHLAND, VIRGINIA 23005  
(804) 550-9200**

**VIRGINIA DEPARTMENT OF CORRECTIONS  
6900 ATMORE DRIVE  
RICHMOND, VIRGINIA 23225**

**NOTTOWAY CORRECTIONAL CENTER UNIT 2  
WASTEWATER TREATMENT PLANT UPGRADES  
D. O. C. Project No. 799-17260**

**ADDENDUM NO. 3  
DATE: June 13, 2008  
P N 94020 33**

**TO: ALL CONTRACT DOCUMENT HOLDERS**

This Addendum No. 3 shall be inscribed in and made part of the above-noted plans, specifications, and contract documents dated March 28, 2008. It is the purpose of this Addendum to incorporate into the project corrections and clarifications. This Addendum No. 3 contains the following:

Drawings:

1 Drawing E-11

Planholder Question:

- a. Panel MDP schedule shows a 45 KVA transformer but the one-line drawing shows an existing 30 KVA transformer. Is the existing one to be replaced with the new 45 KVA one?

Response: yes.

**Acknowledgment of this Addendum No. 3 shall be stated by the bidder on the Bid Form at the appropriate location.**

**\*\*\*\*\*END OF ADDENDUM\*\*\*\*\***